

Message

From: North, Alexis [North.Alexis@epa.gov]
Sent: 12/21/2018 8:56:14 PM
To: Beeler, Cindy [Beeler.Cindy@epa.gov]
Subject: FW: Compressor Station - Component Count

FYI...

From: North, Alexis
Sent: Friday, December 21, 2018 1:56 PM
To: 'Steve Warner' <SWarner@cgrs.com>
Subject: RE: Compressor Station - Component Count

Hi Steve,

I think you're asking if there are NSPS OOOOa fugitive emissions monitoring requirements at compressor stations? I believe **IF** a compressor station is constructed, modified or reconstructed after 9/18/2015 there is monitoring of fugitive emission components at compressor stations per [60.5365a\(j\)](#) and [60.5397a](#). The installation of the new compressors likely triggers a modification per 60.5365a(j)(1):

"60.5365a(j) The collection of fugitive emissions components at a compressor station, as defined in §60.5430a, is an affected facility. For purposes of §60.5397a, a "modification" to a compressor station occurs when: (1) An additional compressor is installed at a compressor station; or"

There isn't a general requirement to have a "count" of fugitive components, unless the facility is using Method 21 to detect fugitive emissions in which case: (1) the fugitive emissions monitoring plan must include a list of fugitive emissions components (see § 60.5397a(d)(3)), and (2) records must be maintained of fugitive emission component identification (see § 60.5420a(c)(15)(F)). Additionally, there are circumstances when information about components is required to be identified, reported or recorded, for example:

- Fugitive components designated as "difficult-to-monitor" or "unsafe-to-monitor" must be identified in separate plans which are incorporated into the fugitive emission monitoring plan, see §§ 60.5397a(g)(3) and (g)(4);
- Annual reports submitted must include the number and type of components for which fugitive emissions were detected, number and type of fugitive emissions components that were not repaired, number and type of difficult-to-monitor and unsafe-to-monitor fugitive emission components monitored, date of successful repair of the fugitive emissions component, and number and type of fugitive emission components placed on delay of repair and explanation for each delay of repair, see § 60.5420a(b)(7);
- Records must be maintained documenting each fugitive emission, including location, number and type of components for which fugitive emissions were detected, number and type of difficult-to-monitor and unsafe-to-monitor fugitive emission components monitored, number and type of fugitive emissions components that were not repaired, number and type of components that were tagged as a result of not being repaired during the monitoring survey when the fugitive emissions were initially found, number and type of fugitive emission components placed on delay of repair and explanation for each delay of repair, and the date of successful repair of the fugitive emissions component, § 60.5420a(c)(15)(I);and

You are correct that there is also rod packing requirements for reciprocating compressor compressors (60.5385a) in addition to the fugitive emissions monitoring.

I hope this helps.

Let me know if you have additional questions,

Alex

Alexis North, Environmental Scientist
Office of Enforcement, Compliance & Environmental Justice
EPA Region 8
1595 Wynkoop Street (8ENF-AT)
Denver, CO 80202-1129
Phone: 303-312-7005
Email: north.alexis@epa.gov

From: Steve Warner <SWarner@cgrs.com>
Sent: Tuesday, December 18, 2018 3:24 PM
To: North, Alexis <North.Alexis@epa.gov>
Subject: Compressor Station - Component Count

Alexis,
Thanks much for the phone chat. Here's a recap of my question, and what I've discovered so far...

Question: Does a compressor station have to complete component counts under OOOOa?

I've asked the client to identify his compressors to know if they are centrifugal or reciprocating. We believe they are reciprocating, so following that path it appears very clear to me that it's all about "rod packing". All maintenance, tracking, reporting, and replacement seems centered around the rod packing. Following all the paths for this compressor I see no discussion on component counts.

A second part to the question is that I know they have installed some new turbine compressors, and I don't know yet if this falls under centrifugal. That too is waiting on the client's comments.

Any thoughts are certainly welcome. Thank you very much for your help!

Steve Warner
Project Engineer
800.288.2657 | mobile 970.631.4876

